


Environmental Series 1/4 HP Air Curtain

| PROJECT LOCATION | | | | ENGINEER ARCHITECT | | CONTRACTOR DATE | | | SHEET OF DRAWING NO. | | |
|--|------------------------------------|--|--|--|---|--|---|-------------------|-------------------------------------|------------|-------------|
| MARK | QTY. | WIDTH | HEIGHT | MODEL NUMBER | MAX. VEL. (FPM) | AVG. VEL. (FPM) | AVG AIRFLOW (CFM) | NO. OF MOTORS | AMPS | WT. LBS | REMARKS |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| SPECIFICATIONS: General: Air curtain unit shall be Leading Edge brand Environmental Series 1/4HP Models. Cabinet: Unit shall be all-metal, corrosion resistant, galvanized steel housing. The maximum effective width per motor blower assembly shall be no more than 48" and all cabinets shall have structural sidewall supports a maximum 48" apart. Units to have full-length discharge and flush louvers with 1-inch directional vanes for maximum 40° sweep for optimum airflow adjustment. Cabinet grill shall allow for no tools access to motor/blower assembly. Electrical junction box shall be mounted on lower right hand side of unit unless otherwise specified. | | | | | Mounting: Each unit shall be constructed with keyholes on the rear of the unit for flush wall mounting and supplied with mounting template and an eight-page Operating Instructions and Parts Manual. Complete Unit: Air Curtain unit shall be UL- or ETL-listed Optional Accessories: ☐ Instant On/Off Accessories: ☐ Automatic Door Switches- for instant activation upon door opening. ☐ Control Panel- for three phase air curtains requiring Automatic Door Switches. | | | | | | |
| double externation to matically ber-sealed | ended sh resetting ball bear | afts. Each mo g Texas Instru rings. Single | otor shall be ruments therm phase motors | otally enclosed, permanent split c esilient mounted and furnished wi al overload and permanently lubric shall be two-speed. Internal moto | th an au- cated rub- or power cord | <i> </i> | <i>Hardware:</i> nt duty Wall Brad dium duty Wall E | cket- for wall mo | ounting of unit unting of unit u | from top o | of cabinet. |
| shall feature quick-disconnect plugs for easy removal of blower base assembly for cleaning and maintenance. Fan Assembly: Blower wheels and scrolls shall be all metal, corrosion-resistant, galvanized steel. Blower wheels shall be directly driven, double-inlet squirrel cage design. The maximum effective width of any individual motor/blower assembly shall hot exceed 48 inches. | | | | | | ☐ Grills: anodized aLuminum architectural grill. ☐ Filters: washable aluminum mesh filters. ☐ Tamper-Resistant Kit: prevents unauthorized access to air curtain motor/blower assembly. | | | | | |



NOTES:

- (1) Refer to individual model number for unit width.
- (2) Keyholes for mounting unit flush to wall accepts 3/8" bolts. Four keyholes are provided per motor (60" unit has only four keyholes). Mounting template is provided with every unit for ease in installation. Mounting hardware and support structure to local code by others.
- (3) All metal, corrosion-resistant, galvanized steel housing and intake grill, with electrostatically applied epoxy finish over powder primer.
- (4) Intake grill knurl nuts allow for no tool access to motor/blower assembly for inspection and cleaning.
- (5) Electrical junction box and two-speed rocker switch (single-phase units) located on standard right hand side, unless otherwise noted.
- (6) Full-length air directional vanes are 1" deep for maximum 40° air directional sweep. Unit should be mounted such that the 40° sweep of air stream is unobstructed.
- (7) Discharge nozzle extends full width for maximum area coverage and efficiency.
- (8) Complete air curtain unit is UL- or ETL-listed and complies with federal FDA and USDA standards.
- (9) All dimensions should be field verified.

| PROJECT | CONTRACTOR | | | | | |
|---|----------------|--|--|--|--|--|
| LOCATION | DATE | | | | | |
| ENGINEER | SHEET OF | | | | | |
| ARCHITECT | DRAWING NUMBER | | | | | |
| A Marley Engineered Products Brand 470 Beauty Spot Road E • Bennettsville, SC 29512 • Phone: (843)479-4006 | | | | | | |
| Fax: (843) 479-8912 • Toll Free 800-452-4179 | | | | | | |

1/4HP ENVIRONMENTAL SERIES MODELS