

LCHWD24 & LCHWD30

PROJECT		ENGINEER		SUBMITTED BY
DATE		ARCHITECT		
SHEET	OF	CONTRACTOR		
27" 33" (24" fan) (30" fan)	26" I-BEAM MOUNT 21" 27" ROUND PEDESTAL BASE AND ADJUSTABLE PEDESTAL COLUMN	Installer supplied 13" CEILING MOUNT 12" WALL MOUNT 12"	lubricated ball bearings, split capacitor motor wit Precision balanced alum Zinc plated guards meeti Rear dome design allows Meets UL 507 spray test Fan motor and mounts a USDA approved for incid OPTIONAL MOUNTS Wall*	chase, 120 volt, totally enclosed, permanently built-in thermal overload protection, permanent h 5' long air actuated pendant switch. inum blades. ing OSHA safety standards. is for servicing or replacement of switch or capacitor. requirements. re coated with FDA approved epoxy paint and are lental food contact.

	MODEL		MODEL	BLADE	FAN	CFM		RPM		MOTOR	MAX	
ITEM	QTY	MARK	NUMBER	SIZE	STYLE	НІ	LOW	н	LOW	H.P.	AMPS	REMARKS

SPECIALITY WASH DOWN SERIES AIR CIRCULATOR

SUBMITTAL SHEET