


MSPH **PLENUM RATED HEATER**

CAPACITIES

3kw to 15kw Watts 208, 240, 277, or 480 V 1Ø and 3Ø





					HEATER					AIR FLOW			
ITEM	QTY.	CAT. NO.	TAG	KW	VOLTS	Ø	AMPS	CONTROL VOLTS	MOTOR VOLT	CFM	TEMP RISE	NO. OF STAGES	BUILT-IN CONTROLS
		·											


ACCESSORIES AND CONTROLS

ITEM	QTY.	CAT. NO.	TAG	DESCRIPTION

SUBMITTED BY:	DATE

APPROVED BY:	DATE

Duct Flanges



CATALOG LOW SPEED** HIG	HIGH SPEED**		
NUMBER PHASE KW VOLTAGE AMPS* CFM RISE CF	M RISE	LBS	HXWXL
MSPH138124 208 15.32			
MSPH132124 1 3 240 13.4			
MSPH137124 277 11.63 350 27°F 40	00 24°F	49	12.5"x19.5"x24
MSPH138324 208 9.23 550 271 40 MSPH132324 3 3 240 8.12			
MSPH132324 3 3 240 8.12 MSPH134324 480 4.11			
MSPH158124 400 4.11 MSPH158124 208 24.94			
MSPH152124 1 5 240 21.73			
MCDU157104 077 10.05			
MSPH157124 277 16.65 350 45°F 40	00 39°F	49	12.5"x19.5"x24"
MSPH152324 3 5 240 12.93			
MSPH154324 480 6.51			
MSPH158124L 208 24.94			
MSPH152124L 1 5 240 21.73			
1 MSPH157124L 277 18.85 850 20°F 10	00 16°F	49	18"x18"x35.5
MSPH158324L 208 14.78	00 101	43	10 X10 X00.0
MSPH152324L 3 5 240 12.93			
MSPH154324L 480 6.51			
MSPH1758124 208 38.12			
MSPH1752124 1 7.5 240 33.31 MSPH1757124 277 28.91 050 200€ 10			
MSPH1757124 277 28.91 850 28°F 10	00 24°F	69	18"x18"x35.5
MSPH1752324 3 7.5 240 20.1			
MSPH1754324 480 10.16			
MCDU4400404 40 040 49 79	0405		
MSPH1102124 1 10 240 43.73 37°F MSPH1107124 277 37.93	31°F		
MCDU9109194 1 10 940 49 79	00 31° / 16°F		
MSPH210/124 2// 3/.93	00 31 / 10 F		
MSPH1108324 208 29.82		•	
MSPH1102324 3 10 240 26.12 37°F	31°F		
MSPH1104324 480 13.17		- 69	18"x18"x35.5"
MSPH2108324 208 29.82	00 040 / 4005	00	10 110 100.0
	00 31° / 16°F		
MSPH2104324 480 13.17 MSPH1158324 208 43.9			
MSPH1150324 3 15 240 38.14 850 56°F 10	00 47°F°		
MSPH1152324 3 15 240 36.14 650 56 F 10 MSPH1154324 480 19.18	00 4/ F		
MCDH0450204 2 45 040 20 44	00 470 (0.00	-	
MSPH2152324 3 15 240 38.14 850 56° / 28°F 10 MSPH2154324 480 19.18	00 47° / 24°F		

*Total Amps including Resistive and Inductive loads.

*Low and High speed fan operation is determined during installation of thermostat set up # 1 Tested @0.2" S.P. Low speed fan operation not available on 480V models.

ARCHITECT'S AND ENGINEER'S SPECIFICATIONS

The electric plenum rated heaters shall be as manufactured by QMark, A Marley Engineered Products Brand

Heaters shall be certified by ETL to standard for heating and cooling equipment ANSI/UL 1995, CAN/CSA C22-2 No. 236.05, third edition, designed for mounting for horizontal discharge. All capacities, voltages, physical sizes, grille arrangements and options shall be as specified in the heater schedule. All three phase heaters shall have a balanced heating load. Control voltage is to be internally generated 24 VAC.

CABINET - The cabinet shall be of 20 gauge all powder coated steel with acoustic fiberglass insulation. The heater front cover shall be securely attached to the cabinet with screws and are easily removable for access to elements, filters and control panel. The inlet and outlet ends of the cabinet are equipped with perforated flanges for duct connection. Cabinet to be finished in a neutral gray powder coat.

HEATING ELEMENTS - The heating elements shall be warranted for five years and shall be of non-glowing design consisting of 80-20 Ni/Cr- resistance wire enclosed in a steel sheath to which steel plate fins are brazed. The heating element shall be located directly in front of the blower discharge air for uniform heating.

SAFETY THERMAL CUTOUTS - Thermal safety cutouts shall be built into the system to automatically shut off heater in event of overheating due to any cause. The safety cutouts shall directly interrupt power to the elements.

MOTOR AND BLOWER ASSEMBLY - The motor(s) and blower(s) shall be direct drive and resiliently mounted on a rigid heavy gauge frame for quiet operation and long life. The motor(s) shall be 1/6 HP or 1/4 HP with automatic reset overload. The 480V units shall be single speed (high); all other units shall be two speed. 208, 240 and 277 volt motors are semi-enclosed and the 480 volt is totally enclosed. Motor fuse protection shall be provided to meet UL, cUL and NEC requirements. The blower(s) shall be forward curved, double inlet, centrifugal type with discharge directly on the full length of the elements to provide uniform discharge air temperatures.

AIR FILTERS- The optional filter kit shall be located ahead of the motor and blower assembly to assure clean air circulation. The filter shall filter the returning room air. Filter shall be easily removed for changing or cleaning by removing the access door and pulling on the filter. A disposable filter is standard and a permanent washable filter is optional.

DISCONNECT SWITCH -

The unit shall have a 80 amp 3 pole disconnect for single point connection

FAN DELAY CONTROL - Fan control shall delay fan start up of the fan motor(s) until the heating elements have warmed up. It shall maintain motor operation after heating

elements have been de-energized to dissipate residual

TEMPERATURE CONTROL - The unit is designed to be controlled by a remote 24 Volt thermostat. thermostat connections are made at the control terminal board.

HEAT SELECTION / FAN SPEED - Two fan speeds and high-low heat ranges shall be selectable by means of the remote thermostat.

The following Factory Installed / prewired Equipment shall be supplied -

- Auto Reset Thermal Cutout
- 24V Control Supply
- Time Delay Relay Disconnect Switch
- Inlet / Discharge Duct Collars

The following Field Installed Optional Equipment shall be supplied -

- Filter Rack
- Louver Rack
- Aluminum Wall Louver
- Electronic Digital 2 Stage 24V control

DIMENSIONS - Small Cabinet

24.00 12.50 19.50 舠 3/8' KNOCKOUT THERMOSTAT 7/8' KNOCKOUT - POWER SUPPLY (SERVES AS PILOT HOLE FOR LARGER FIELD WIRING NEEDS)

DIMENSIONS - Large Cabinet

