PRODUCT SUBMITTAL SHEET

Submitted By:



Job Name:_

Capacities

500, 562, 750, 900, 1000, 1125, 1500, 1800 or 2000 Watts 120, 208, 240 or 277V @ 1Ø Only

Thermostat Range: 40° - 85° F Air Movement: 65 CFM

SRA SERIES FAN-FORCED WALL HEATERS

Date:

Location:										
Architect:_										
Engineer:	Approved By:				Date:					
Contractor:	Approved by:				Tute.					
Submitted	Ву:									
Date:										
	Ι	Catalog								
Item	QTY	Number	Tag	Wa	tts	Volts	PH	AM	PS	Weight

Tag



QTY


Item




ACCESSORIES

Part

Number



Volts	Amps	Watts	BTU/HR	Wire Size				
120	8.4/4.2	1000/500	3413/1706	14AWG				
120	12.5/6.3	1500/750	5120/2560	12AWG				
120	15.0/7.5	1800/900	6143/3072	12AWG				
240	8.4/4.2	2000/1000	6826/3413	14AWG				
208	7.3/3.6	1500/750	5120/2560	14AWG				
277	7.3/3.6	2000/1000	6826/3413	14AWG				
240	6.3/3.2	1500/750	5120/2560	14AWG				
277	5.5/2.75	1500/750	5120/2560	14AWG				
240	4.7/2.4	1125/562	3840/1920	14AWG				
208	9.6/4.8	2000/1000	6826/3413	14AWG				
SRASM Surface Mounting Frame (Accessory) Order Separately 12-1/2" (318mm)H X 10-3/8" (264mm)W X 4" (102mm) - Northern White								
SRAS2 2" (50mm) Recess Mounting Frame (Accessory) Order Separately - Northern White								
	120 120 120 240 208 277 240 277 240 208 ace Mounting /2" (318mm) 5mm) Recess	120 8.4/4.2 120 12.5/6.3 120 15.0/7.5 240 8.4/4.2 208 7.3/3.6 277 7.3/3.6 240 6.3/3.2 277 5.5/2.75 240 4.7/2.4 208 9.6/4.8 ace Mounting Frame (Accessor /2" (318mm)H X 10-3/8" (264 5mm) Recess Mounting Frame	120 8.4/4.2 1000/500 120 12.5/6.3 1500/750 120 15.0/7.5 1800/900 240 8.4/4.2 2000/1000 208 7.3/3.6 1500/750 277 7.3/3.6 2000/1000 240 6.3/3.2 1500/750 277 5.5/2.75 1500/750 240 4.7/2.4 1125/562 208 9.6/4.8 2000/1000 ace Mounting Frame (Accessory) Order Separatel /2" (318mm)H X 10-3/8" (264mm)W X 4" (102m 5mm) Recess Mounting Frame (Accessory) Order	120 8.4/4.2 1000/500 3413/1706 120 12.5/6.3 1500/750 5120/2560 120 15.0/7.5 1800/900 6143/3072 240 8.4/4.2 2000/1000 6826/3413 208 7.3/3.6 1500/750 5120/2560 277 7.3/3.6 2000/1000 6826/3413 240 6.3/3.2 1500/750 5120/2560 277 5.5/2.75 1500/750 5120/2560 277 5.5/2.75 1500/750 5120/2560 240 4.7/2.4 1125/562 3840/1920 208 9.6/4.8 2000/1000 6826/3413 acc Mounting Frame (Accessory) Order Separately /2" (318mm)H X 10-3/8" (264mm)W X 4" (102mm) - Northern Wh				



ARCHITECT'S AND ENGINEER'S SPECIFICATIONS*

SRAFCTP

The heating equipment shall include an electric automatic fan forced air heater suitable for small area heating, as manufactured by Berko®, a Marley Engineered Products® Brand, Bennettsville, SC. The heater shall be designed for wall mounting, recess or surface. Heaters shall be cETLus listed.

Tamper-resistant front cover - Northern White

BACK BOX: The back box shall be designed as a recessed rough-in box in either masonry or frame installations and is also used when surface mounting frames are used in surface mounting installations. The back box shall be heavy gauge galvanized steel and shall contain knockouts through which power leads enter.

INNER FRAME ASSEMBLY: The heater assembly, which fits into the back box, shall consist of a heavy gauge steel fan panel to which all of the operational parts of the heater are mounted. The inner frame assembly shall be completely prewired.

HEATING ELEMENT: The heating element shall be of the non-glowing design consisting of an 80/20 nickel-chromium resistance wire enclosed in a steel sheath to which plate fins are copper brazed. The element shall cover the entire air discharge area to ensure uniform heating of all discharged air. It shall be warrantied for 5 years.

ON/OFF SWITCH: A double-pole, single throw on/off switch shall be mounted on the back box for positive disconnect of power supply. It will be completely concealed behind the front cover.

MOTOR AND CONTROLS: The fan motor shall be impedance protected, permanently lubricated. Fan control shall be of the bi-metallic, snap-action type and shall activate fan after heating element reaches operating temperature, and continue to operate the fan after the thermostat is satisfied and until all heated air has been discharged. The thermostat shall be single-pole type on all models. Thermal cutout shall be self-hold (manual-reset) type designed to shut off heat in the event of overheating. The fan shall be four-bladed aluminum. A back-up (End of Life) thermal fuse shall be provided for additional safety.

SURFACE MOUNTING FRAME: The surface mounting frame shall be of heavy gauge steel designed to mount around the back box for a finished surface installation. Slot knock outs shall be provided for power supply conduit.

FRONT COVER: The louvered front cover shall be of heavy gauge steel with a powder paint finish. A plug button will be provided to replace the thermostat knob and render the unit tamper-resistant.

FINISH: All sheet metal parts, except the galvanized steel back box, shall be phosphatized, then completely painted by a powder paint process.

*In the interest of continual improvements in product and performance, Marley Engineered Products reserves the right to change specifications without notice.