PRODUCT SUBMITTAL SHEET

Submitted By:



Capacities

SRA ARCHITECTURAL SERIES FAN-FORCED WALL HEATERS

Date:


500, 562, 750, 1000, 1125, 1500, 2000 Watts 120, 208, 240 or 277V 1Ø only Thermostat Range: 40° - 90° F Air Movement: 65 CFM MAX

Job Nar	ne:				ubmi	tted By:				Date:
Locatio	n:									
				Approved By:			Date:			
									_	
Date: _										
Item	QTY	Catalog Number	Tag	Watt	S	Volts	PH	AM	PS	Weight
		ACCESSORIES			[T
Item	QTY	Part Number	Tag		1				C	
]= <i>e</i>	•	NTERTER							
	Ma	rley°	INTERTER CHARLES							









SELECTION CHART

CATALOG NUMBER	VOLTS	AMPS	WATTS	BTU/HR.	WIRE SIZE				
SRA1012DSAF	120	8.4	1000	3413	14 AWG				
3NA 1012D3AF	120	4.2	500	1706	14 AVVU				
SRA1512DSAF	120	12.5	1500	5120	12 AWG				
3NA 1312D3AF	120	6.25	750	2560	12 AVVG				
SRA1812DSAF	120	15	1800	6143	12 AWG				
	240	8.4	2000	6826					
SRA2024DSAF	240	4.2	1000	3413	14 AWG				
3KAZUZ4D3AF	200	7.3	1500	5120	T4 AWG				
	208	3.61	750	2560	\neg				
	277	7.3	2000	6826					
SRA2027DSAF	211	3.61	1000	3413	14 AWG				
SNAZUZ <i>I</i> DSAF	240	6.25	1500	5120	14 AVVG				
	240	3.2	750	2560					
	277	5.5	1500	5120					
SRA1527DSAF	211	2.75	750	2560	14 AWG				
3NA 1327 D3AF	240	4.7	1125	3840	14 AVVG				
	240	2.35	562	1920					
CDAGGGGAF	208	9.6	2000	6826	14 0000				
SRA2020DSAF	200	4.8	1000	3413	14 AWG				
CATALOG NUMBER	DESCRIPTION								
SRASMAG	Surface Mounting Frame (Accessory). Order separately. 12-1/2"H x 10-3/8"W x 4"D - Statuary Bronze								
SRAS1AG	1" Semi-recess Mounting Frame, 12-1/2"H x 10-3/8"W x 1"D - Statuary Bronze								
SRAS2AG	2" Semi-recess Mounting Frame, 12-1/2"H x 10-3/8"W x 2"D - Statuary Bronze								

ARCHITECT'S AND ENGINEER'S SPECIFICATIONS

The heating equipment shall include an electric automatic fan forced air heater suitable for small area heating, as manufactured by Berko®, A Marley Engineered Products Brand, Bennettsville, SC. The heater shall be designed for wall mounting, recess or surface. Heaters shall be UL listed or equivalent (ETL).

BACKBOX: The backbox shall be designed for duty as a recessed rough-in box in either masonry or frame installations and is also used with the surface mounting frame in surface mounting installations. The backbox shall be heavy gauge galvanized steel and shall contain knockouts through which power leads are brought.

INNER FRAME ASSEMBLY: The heater assembly which fits into the backbox shall consist of a heavy gauge steel fan panel upon which is mounted all of the operational parts of the heater. The inner frame assembly shall be completely pre-wired.

HEATING ELEMENT: The heating element shall be of the non-glowing design consisting of an 80/20 nickel-chromium resistance wire enclosed in a steel sheath to which plate fins are copper brazed. It shall be warranted for 5 years. The element shall cover the entire air discharge area to ensure uniform heating of all discharge air.

POWER ON/OFF SWITCH: A double-pole single throw ON/OFF switch shall be mounted on the back box for positive disconnect of power supply. It will be completely concealed behind the front cover.

MOTOR AND CONTROLS: The fan motor shall be impedance protected, permanently lubricated and with totally enclosed rotor. Fan control shall be of the bi-metallic, snapaction type and shall activate fan after heating element reaches operating temperature, and continue to operate the fan after the thermostat is satisfied and until all heated air has been discharged. The thermostat shall be single pole type on all models. Manual-reset thermal cutout shall be bi-metallic, snapaction type designed to shut off heat in the event of overheating. The fan shall be four-bladed aluminum.

SURFACE MOUNTING FRAME: The surface mounting frame shall be of heavy gauge steel designed to mount around the backbox for a finished surface installation. Slot knock outs shall be provided for power supply conduit.

FRONT COVER: The louvered front cover shall be of heavy gauge steel with a polyester powder coat finish. A plug button will be provided to replace the thermostat knob and render the unit tamper-resistant.

FINISH: All sheet metal parts, except the galvanized steel backbox, shall be phosphatized, then completely painted by a powder paint process.

*Berko reserves the right to change specifications without prior notice.